

# CERTIFICATE

## FOR EUROPEAN PRODUCT SAFETY

Reference No. SE-S-2001581

### Low-voltage switchgear and controlgear - Part 2: Circuit-breakers

<b>Type designation:</b>	EPB-125H, EPB-125L, SGB-125H, SGB-125L
<b>Certificate holder:</b>	MAXGE ELECTRIC TECHNOLOGY CO., LTD No. 299 East Changhong Road, Deqing Economic Zone, Wukang, Deqing, Zhejiang, China
<b>The product complies with the standard(s):</b>	EN 60947-2:2017
<b>Date of expiry:</b>	26 May, 2025
<b>EU Directive information:</b>	According to the principle of presumption of conformity, this certificate constitutes support for an EC Declaration of Conformity and CE marking according to the Low Voltage Directive 2014/35/EU.

Additional information in Appendix

**Certification Body:** Intertek Semko AB, Product Certification **Place:** Kista - Stockholm

**Signed:**  **Date:** 26 May, 2020

Leif Mattsson

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

# Test Verification of Conformity

Verification Number: 200200463SHA-V1

On the basis of the referenced test report(s), sample(s) tested of the below product have been found to comply with the standards harmonized with the directives listed on this verification at the time the tests were carried out. Other standards and Directives may be relevant to the product. This verification is part of the full test report(s) and should be read in conjunction with it <them>.

Once compliance with all product relevant **CE** mark directives are verified, including any relevant e.g. risk assessment and production control, the manufacturer may indicate compliance by signing a Declaration of Conformity themselves and applying the mark to products identical to the tested sample(s).

Applicant Name & Address:	MAXGE ELECTRIC TECHNOLOGY CO., LTD No. 299 East Changhong Road, Deqing Economic Zone, Wukang, Deqing, Zhejiang, China.
Manufacturing site Name & Address:	MAXGE ELECTRIC TECHNOLOGY CO., LTD No. 299 East Changhong Road, Deqing Economic Zone, Wukang, Deqing, Zhejiang, China.
Product Description:	Low-voltage switchgear and controlgear - Part 2: Circuit-breakers
Ratings & Principle Characteristics:	Ue= 240V for 1P, 415V for 2P, 3P, 4P In= 40, 50, 63, 80, 100, 125A; EPB-125H, SGB-125H: Icu=10kA, Ics=7,5kA EPB-125L, SGB-125L: Icu= Ics=6kA Cat. A, Ii=10In, Uimp=4kV, Ui=690V, 50/60Hz ref. temperature +50°C and +30°C
Models/Type References:	EPB-125H, EPB-125L, SGB-125H, SGB-125L
Brand Name(s):	<b>MAXGE</b>
Standard(s)/Directive(s):	EN 60947-2: 2017 Low Voltage Directive 2014/35/EU
Verification Issuing Office Name & Address:	Intertek Testing Services Shanghai Building No.86, 1198 Qinzhou Road (North), Shanghai 200233, China
Date of Tests:	2020-02-11 to 2020-04-26
Test Report Number(s):	200200463SHA-001, 200200463SHA-002



**Signature**

**Name: Oliver Wei**  
**Position: Manager**  
**Date: 28 May 2020**

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.



Ref. Certif. No.  
**SE-101191**

**IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME**

**CB TEST CERTIFICATE**

Product	Circuit-breakers
Name and address of the applicant	MAXGE ELECTRIC TECHNOLOGY CO., LTD No. 299 East Changhong Road, Deqing Economic Zone, Wukang, Deqing, Zhejiang, China
Name and address of the manufacturer	Same as applicant
Name and address of the factory <i>Note: When more than one factory, please report on page 2</i>	Same as applicant
Ratings and principal characteristics	See page 2
Trademark (if any)	
Customer's Testing Facility (CTF) Stage used	-
Model / Type Ref.	SGB-125H, SGB-125L
Additional information (if necessary may also be reported on page 2)	-
A sample of the product was tested and found to be in conformity with	IEC 60947-2:2016+A1
As shown in the Test Report Ref. No. which forms part of this Certificate	200200463SHA-002

This CB Test Certificate is issued by the National Certification Body

**Intertek Semko AB**  
Torshamnsgatan 43  
Box 1103  
SE-164 22 Kista, Sweden



Signature:

Date: 26 May, 2020

Leif Mattsson