

Zertifikat

Certificate



Zertifikat Nr. *Certificate No.*
R 50482661

Blatt *Sheet*
0001

Ihr Zeichen <i>Client Reference</i>	Unser Zeichen <i>Our Reference</i>	Ausstellungsdatum <i>Date of Issue</i>
X.X.B	01-Wuchale-60407139 001	15.10.2020 (day/mo/yr)

Genehmigungsinhaber *License Holder*
MAXGE ELECTRIC
TECHNOLOGY CO., LTD.
NO. 299 EAST CHANGHONG ROAD
DEQING ECONOMIC ZONE, WUKANG
DEQING
313200 Zhejiang
P.R. China

Fertigungsstätte *Manufacturing Plant*
MAXGE ELECTRIC
TECHNOLOGY CO., LTD.
NO. 299 EAST CHANGHONG ROAD
DEQING ECONOMIC ZONE, WUKANG
DEQING
313200 Zhejiang
P.R. China

Prüfzeichen *Test Mark*



Type Approved
Safety
Regular Production
Surveillance

www.tuv.com
ID 111230394

Geprüft nach *Tested acc. to*
IEC 60947-3:2020

Zertifiziertes Produkt (Geräteidentifikation)
Certified Product (Product Identification)

Lizenzentgelte - Einheit
License Fee - Unit

Fuse Holder (Fuse base for Fuse-disconnector)

Type Designation	: (1) EPF 32	6
	(2) EPF 32/2P	1
	(3) EPF 32/3P	1
	(4) EPF 32/4P	1
Utilization Category	: AC-20B	
Rated Operational Voltage (Ue)	: (1) AC 250 V	
	(2) - (4) AC 500 V	
Rated Operational Current (Ie)	: 2 - 32 A	
Rated Insulation Voltage (Ui)	: 500 V	
Rated Impulse Withstand Voltage (Uimp)	: 4 kV	
Conventional Free Air Thermal Current (Ith)	: 32 A	
Rated Conditional Short-circuit Current	: 20 kV	
Pollution Degree	: 3	

9

ANLAGE (Appendix): 1.0

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.
This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

Tel.: +49 221 806-1371 e-mail: cert-validity@de.tuv.com
Fax: +49 221 806-3935 http://www.tuv.com/safety

Zertifizierungsstelle



Bo Liu

MAXGE ELECTRIC TECHNOLOGY CO., LTD.
Xu Xiangbing

Date : 15.10.2020
Our ref. : Wuchale 01
Your ref.: X.X.B

NO. 299 EAST CHANGHONG ROAD
DEQING ECONOMIC ZONE, WUKANG
DEQING
313200 Zhejiang
P.R. China

Ref : R TÜV-Mark Approval

Type of Equipment : Fuse base for Fuse-disconnector
Model Designation : See Certificate
Certificate No. : R 50482661 0001
Report No. : 60407139 001

Dear Xu Xiangbing,

The above specified technical equipment has been tested and found to be in accordance with the relevant requirements.

Enclosed you will find the certificate of approval.

If cancellation of the certificate is submitted by November 15 in a given year, no fee will be charged for the following year.

We appreciate your kind support and would like to offer our assistance and continuous services in the future.

Please contact our office for approval of your new products.

With kind regards,



Certification Body

Bo Liu



Enclosure

证书的详细资料请登录www.tuvdotcom.com 查阅, 或拨打我司客服热线 800 999 3668/400 883 1300 咨询

Prüfbericht-Nr.: Test Report No.:	60435158 001	Auftrags-Nr.: Order No.:	190126857	Seite 1 von 49 Page 1 of 49
Kunden-Referenz-Nr.: Client Reference No.:	2028398	Auftragsdatum: Order date:	2020-06-17	
Auftraggeber: Client:	MAXGE ELECTRIC TECHNOLOGY CO., LTD. NO. 299 EAST CHANGHONG ROAD DEQING ECONOMIC ZONE, WUKANG, DEQING, ZHEJIANG 313200 P.R. China			
Prüfgegenstand: Test item:	Fuse base for Fuse-disconnector			
Bezeichnung / Typ-Nr.: Identification / Type No.:	EPF 32, EPF 32/2P, EPF 32/3P, EPF 32/4P			
Auftrags-Inhalt: Order content:	CE-LVD CoC			
Prüfgrundlage: Test specification:	EN 60947-3:2009/A2:2015			
Wareneingangsdatum: Date of sample receipt:	2020-07-15			
Prüfmuster-Nr.: Test sample No.:	Engineering sample			
Prüfzeitraum: Testing period:	2020-07-18 - 2020-09-30			
Ort der Prüfung: Place of testing:	ZTME			
Prüflaboratorium: Testing laboratory:	TÜV Rheinland (China) Ltd.			
Prüfresultat*: Test result*:	Pass			
geprüft von: tested by:				
Datum: Date:	2021-01-20	Ausstellungsdatum: Issue date:	2021-01-20	+08'00'
Stellung / Position:	Sachverständige(r)/Expert	Stellung / Position:	Sachverständige(r)/Expert	
Sonstiges / Other:				
Attachment 1: Equipment list				
Attachment 2: Photo Documentation				
Zustand des Prüfgegenstandes bei Anlieferung: Condition of the test item at delivery:		Prüfmuster vollständig und unbeschädigt Test item complete and undamaged		
<p>* Legende: 1 = sehr gut 2 = gut 3 = befriedigend 4 = ausreichend 5 = mangelhaft P(ass) = entspricht o.g. Prüfgrundlage(n) F(ail) = entspricht nicht o.g. Prüfgrundlage(n) N/A = nicht anwendbar N/T = nicht getestet</p> <p>Legend: 1 = very good 2 = good 3 = satisfactory 4 = sufficient 5 = poor P(ass) = passed a.m. test specification(s) F(ail) = failed a.m. test specification(s) N/A = not applicable N/T = not tested</p>				
<p>Dieser Prüfbericht bezieht sich nur auf das o.g. Prüfmuster und darf ohne Genehmigung der Prüfstelle nicht auszugsweise vervielfältigt werden. Dieser Bericht berechtigt nicht zur Verwendung eines Prüfzeichens. <i>This test report only relates to the a. m. test sample. Without permission of the test center this test report is not permitted to be duplicated in extracts. This test report does not entitle to carry any test mark.</i></p>				



Ref. Certif. No.

HU-003298

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Fuse-disconnector
Name and address of the applicant	MAXGE ELECTRIC TECHNOLOGY CO., LTD. NO. 299 EAST CHANGHONG ROAD DEQING ECONOMIC ZONE, WUKANG, DEQING, 313200 Zhejiang, P.R. China
Name and address of the manufacturer	MAXGE ELECTRIC TECHNOLOGY CO., LTD. NO. 299 EAST CHANGHONG ROAD DEQING ECONOMIC ZONE, WUKANG, DEQING, 313200 Zhejiang, P.R. China
Name and address of the factory	MAXGE ELECTRIC TECHNOLOGY CO., LTD. NO. 299 EAST CHANGHONG ROAD DEQING ECONOMIC ZONE, WUKANG, DEQING, 313200 Zhejiang, P.R. China
Ratings and principal characteristics	Ue: AC 250 or AC 500 V; Ui: 500V; Ith: 32A; Ie: 2~32A; AC-20B Conditional short-circuit current: 20kA;
Trademark (if any)	MAXGE (see Test Report for logo)
Customer's Testing Facility (CTF) Stage used	N/A
Model / Type Ref.	EPF 32 , EPF 32/2P , EPF 32/3P , EPF 32/4P
Additional information (if necessary may also be reported on page 2)	---
A sample of the product was tested and found to be in conformity with	IEC 60947-3:2020 IEC 60947-1:2020
As shown in the Test Report Ref. No. which forms part of this Certificate	60407139 001

This CB Test Certificate is issued by the National Certification Body



TÜV Rheinland InterCert Kft., MEEI Division
H-1143 Budapest, Gizella út 51-57., Hungary
Web:www.tuv.com

Date: 2021-02-03

Signature:

Petra Szabadi