BV LCIE CHINA Number N° 2166AS02MXG38414

# ATTESTATION
# of conformity with European Directives

| | |
|---|---|
| *Product:* | **MCB** |
| *Reference* | **EPB-63Se/ EPB-63Ne/ EPB-63Me** |
| *Issued to* | **MAXGE ELECTRIC TECHNOLOGY CO., LTD** |
| *Address* | **NO.299 EAST CHANGHONG ROAD, DEQING ECONOMIC DEVELOPMENT ZONE WUKANG DEQING, ZHEJIANG -CHINA** |
| *Manufacturer* | **MAXGE ELECTRIC TECHNOLOGY CO., LTD** |
| *Technical characteristics* | **Type C**<br>**Ue=(230/400V)(240/415V)~ (1P); 230/240V~ (1P+N); 230/240/400/415V~(2P); 400/415V~ (3P;3P+N;4P)**<br>**In=1; 2; 3; 4; 6;10;13; 16; 20; 25; 32; 40; 50; 63A**<br>**EPB-63Me:Ics=Icn=6000A**<br>**EPB-63Ne: Ics=Icn=4500A**<br>**EPB-63Se: Ics=Icn=3000A**<br>**Energy limit class: 3 for 6000A ; 1 for 4500A and 3000A (according to EN 60898-1)**<br>**Grid distance: 45mm for 6000A and 4500A; 35mm for 3000A**<br>**Ui=500V**<br>**Uimp=4kV**<br>**Screw diameter of load terminal =4,9mm** |

**The submitted sample of the above equipment has been tested for CE marking according to following European Directive and following standards:**

**Low Voltage Directive 2014/35/EU**

| *Standards* | *Report number* | *Report date* |
|---|---|---|
| **EN 60898-1:2019** | **B200098** | **2021-02-03** |

The referred test report(s) show that the product complies with standard(s) recognized as giving presumption of compliance with the essential requirements in the specified European Directive

This verification does not imply assessment of the production of the product
The CE marking may be affixed if all relevant and effective European Directives with CE are applicable

**Shanghai (P.R. China), February 18th, 2021.**

**Charlie CHEN**
**Product Line Manager**

CE



**LCIE CHINA**
必维欧亚电气技术咨询服务(上海)有限公司
**Building 4, No. 518, Xin Zhuan Road, CaoHejing Songjiang High-Tech Park, Shanghai P.R.C (201612)**
Tel: +86 21 6195 7000
Fax: +86 21 6195 7001
Email:contact@cn.bureauveritas.com

Test Report issued under the responsibility of:

# TEST REPORT
## IEC 60898-1
## Circuit-breakers for over current protection for household and similar installations
## Part 1 - Circuit-breakers for a.c. operation

| | |
|---|---|
| **Report Number. ..... :** | B200098 |
| **Date of issue ..... :** | 2021-02-03 |
| **Total number of pages ..... :** | 197 pages |
| **Name of Testing Laboratory preparing the Report ..... :** | **Technical center of Wenzhou Entry-Exit Inspection and Quarantine Bureau** |
| **Applicant's name ..... :** | MAXGE ELECTRIC TECHNOLOGY CO., LTD |
| **Address ..... :** | NO.299 EAST CHANGHONG ROAD, DEQING ECONOMIC DEVELOPMENT ZONE WUKANG DEQING, ZHEJIANG -CHINA |
| **Test specification:** | |
| **Standard ..... :** | IEC 60898-1:2015, AMD1:2019 |
| **Test procedure ..... :** | CB Scheme |
| **Non-standard test method ..... :** | N/A |
| **Test Report Form No. ..... :** | IEC60898_1E |
| **Test Report Form(s) Originator .... :** | DEKRA Certification B.V. |
| **Master TRF ..... :** | Dated 2020-04-17 |



If this Test Report Form is used by non-IECEE members, the IECEE/IEC logo and the reference to the CB Scheme procedure shall be removed.

**This report is not valid as a CB Test Report unless signed by an approved CB Testing Laboratory and appended to a CB Test Certificate issued by an NCB in accordance with IECEE 02.**

**General disclaimer:**

The test results presented in this report relate only to the object tested.
This report shall not be reproduced, except in full, without the written approval of the Issuing CB Testing Laboratory. The authenticity of this Test Report and its contents can be verified by contacting the NCB, responsible for this Test Report.